

## Church & Chetwynd Aston Village Hall PAT Testing Log Sheet

Reference Number	Appliance Description	Appliance Location	Class	Rating (A)	Fuse Rating	Visual Inspection	Insulation Resistance	Earth Continuity	Polarity	Ready to Use?	Test Equipment Used	Serial Number	Tested by	Date
VH1	Panasonic Microwave	Kitchen	1	13A	13A	OK	>300M	0.03	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH2	Black nBreville Kettle 1	Kitchen	1	13A	13A	OK	>300M	0.06	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH3	Black Breville Kettle 2	Kitchen	1	13A	13A	OK	>300M	0.05	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH4	Charles Vacuum	Kitchen	2	5A	13A	OK	>300M	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH5	Russell Hobbs Toaster	Kitchen	1	6A	13A	OK	>300M	0.05	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH6	Russell Hobbs Fridge	Kitchen	1	13A	13A	OK	>300M	0.07	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH7	Easy Home Dehumidifier	Storeroom cupboard 3	2	0.6A	3A	OK	>300M	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH8	Chocolate Fountain	Storeroom cupboard 3	2	0.1A	3A	OK	>300M	0.10	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH9	Grey Breville Kettle 1	Storeroom cupboard 3	1	13A	13A	OK	>300M	0.03	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH10	Grey Breville Kettle 2	Storeroom cupboard 3	1	13A	13A	OK	>300M	0.04	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH11	Star Christmas Lights	Storeroom cupboard 3	2	0.1A	N/A	OK	>300M	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH16	Flood Light	Storeroom cupboard 3	2	0.1a	N/A	OK	>300M	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH12	Hoover (bowls)	Storeroom	2	6A	13A	OK	>300M	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH13	IEC Lead	Electric Cupboard	1	5A	5A	OK	>300M	0.09	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH14	IEC Lead	Electric Cupboard	1	10A	10A	OK	>300M	0.06	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH15	Extension Lead	Electric Cupboard	1	13A	13A	OK	>300M	0.09	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH17	One Power Batt. Charger	Aston Room	2	0.1A	N/A	OK	>300M	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH18	5A IEC lead	Aston Room	1	5A	5A	OK	>300M	0.09	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH19	Wharfdale Speaker	Aston Room	1	2A	2A	OK	>300M	0.10	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH20	Q Accoustics Sub-woofer	Aston Room	2	1A	3A	OK	>300M	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH21	Repeater	Aston Room	2	0.1A	N/A	OK	>300M	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH22	Denon Amp	Aston Room	2	2A	5A	OK	>300M	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH23	Panasonic DVD	Aston Room	2	2A	5A	OK	>300	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH24	WIFI	Aston Room	2	0.1A	N/A	OK	>300	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH25	Extensionl lead	Aston Room	1	13A	13A	OK	>300	0.06	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH26	Screen	Main Hall	2	2A	5A	OK	>300	N/A	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023
VH27	Heater	Lobby	1	13A	13A	OK	250M	0.05	Y	Y	Robin SMARTPAT 3500	8726 003	ADM	20/05/2023